

POLLUTANT MONITORING RESULTS EPL20609

Date Monitoring Data Obtained	Sampling Point as per EPL20601	No of times sampled in reporting period	Pollutant	Monitoring Frequency	Monitoring Result	Unit	Pollutant Limit as per EPL20601	Exceedance Y/N	Comments
26 / 09 / 17	1	1	pH	Six monthly	6.8	pH units	6.5-8.5	N	No discharge at time of sampling
26 / 09 / 17			Total Suspended Solids	Six monthly		mg/l	30	N	No discharge at time of sampling
14 / 03 / 18	1	2	pH	Six monthly	7.72	pH units	6.5-8.5	N	No discharge at time of sampling
14 / 03 / 18			Total Suspended Solids	Six monthly	14	mg/l	30	N	No discharge at time of sampling
10 / 10 / 18	1	1	pH	Six monthly	7.95	pH units	6.5-8.5	N	No discharge at time of sampling
10 / 10 / 18			Total Suspended Solids	Six monthly	16	mg/l	30	N	No discharge at time of sampling
9 / 04 / 19	1	1	pH	Six monthly	8.35	pH units	6.5-8.5	N	No discharge at time of sampling
9 / 04 / 19			Total Suspended Solids	Six monthly	16	mg/l	30	N	No discharge at time of sampling